



MODEL	A			VOLUME		DOME VOLUME			WEIGHT		
	mm	inch	+/- mm inch	Liters	U.S. GAL	CUBIC FT	Liters	U.S. GAL	CUBIC FT	Kg	LBS
9×17	431	16.97	4	.16	13.7L	0.48	1.30	0.34	0.05	3.21	7.06
9×35	896	35.28	4	.16	31.6L	1.12	1.30	0.34	0.05	5.65	12.43
9×42	1074	42.28	5	.20	38.2L	1.35	1.30	0.34	0.05	6.76	14.87
9×48	1228	48.35	5	.20	44.6L	1.58	1.30	0.34	0.05	7.86	17.29
9×18	459	18.07	5	.20	14.7L	0.52	1.30	0.34	0.05	3.41	7.50
9×40	1018	40.08	5	.20	36.3L	1.28	1.30	0.34	0.05	6.42	14.12
9×24	610	24.02	5	.20	20.4L	0.72	1.30	0.34	0.05	4.21	9.26

NOTES:

- TANK MUST MEET ALL APPLICABLE SPECIFICATIONS OF NSF/ANSI 044 STANDARD, LATEST REVISION.
- OPERATING SPECIFICATIONS:
 - A. MAXIMUM WORKING PRESSURE - 150 PSI (10.5BAR)
 - B. TEMPERATURE RANGE - 34-120° F (1-49°C)
 - C. MAXIMUM VACUUM - 5"Hg (127mm Hg)
- VISUAL LINER INSPECTION
 - A. NO MORE THAN 10 INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS.
 - B. NO INTERNAL OR EXTERNAL BLEMISHES OR BURNT DEBRIS LARGER THAN 3×3mm.
 - C. NO INTERNAL BLEMISHES OR BURNT DEBRIS ALLOWED.
- ALL GLASS STRANDS FROM FIBERGLASS LINER TO BE BONDED AND COVERED.
- SURFACE TO BE FREE OF NICKS, SCRATCHES, RESIN AND GLASS.
- SURFACE FINISH.
- DIMENSIONS IN PARENTHESES ARE REFERENCE ONLY.
- DIMENSIONS IN SQUARE PARENTHESES ARE INCH UNIT.

THIS DIMENSION CAN BE CHANGED WITH THE CUSTOMERS' REQUIREMENT

0	THIS DRAWING IS UPDATED COMPLYING WITH THE CHINESE VERSION		2008/07/21
VERSION NO.	DESCRIPTION OF CHANGES:	SIGNATURE:	DATE
REPRESENTATIONAL PLASTIC SHRINKAGE (IF NECESSARY):			
SIGNATURE		DATE	
DESIGN	NAME	DATE	
INSPECTION			
APPROVAL			
SCALE		MATERIAL	MODEL
1 : 2			DESCRIPTION
QUANTITY		SMOOTHNESS	9" (DI TANK) FRP VESSEL (STANDARD BASE)
PROJECTION		COMPUTER CODE	DRAWING NO.
THIS PRODUCT DRAWING CAN NOT BE COPIED AND/OR USED WITHOUT PRIOR WRITTEN APPROVAL OF WAVE CYBER.			1160911-00
DO NOT MEASURE THE DIMENSIONS.		UNIT: MM	VERSION NO.
			0
		TOTAL PAGE: 1	

WAVE CYBER (SHANGHAI) CO., LTD.